



Certification Record

CUSTOMER	CLASS	FILE
Hillsdale Terminal & Tools 2222 Moore Rd, Jonesville MI 49250 USA	6223-02 WIRE CONNECTING DEVICES-Wire Connectors	207131
Refer to Class Description for program details		

TO THE REQUIREMENTS OF C22.2 NO 65-03:

- Wire connectors (ring, spade and hook terminals), un-insulated, Part Nos. 10020, 10030, 10040, 10040M, 10041, 10042, 10043, 10044, 10050, 10051, 10052, 1005510060, 10061, 10062, 10070, 10071, 10072, 10085, 10086, 10090, 10100, 10100M, 10101, 10102, 10103, 10104, 10105, 10110, 10114, 10120, 10130, 10140, 10141, 10142, 10150, 10151, 10152, 10160, 10161, 10162, 10165, 10210, 10220, 10230, 10233, 10234, 10240, 10241, 10245, 10250, 10260, 10270, 10271, 10272, 10280, 10281, 10282, 10290, 10291, 10292, may be followed by BZ.
- Insulated type; extruded vinyl, rated 75C, 600V, Part Nos. 20020, 20030, 20040, 20040M, 20041, 20042, 20044, 20050, 20051, 20052, 20055, 20060, 20061, 20062, 20070, 20071, 20072, 20085, 20086, 20090, 20100, 20100M, 20101, 20102, 20103, 20104, 20105, 20110, 20114, 20120, 20130, 20140, 20141, 20142, 20150, 20151, 20152, 20160, 20161, 20162, 20165, 20210, 20220, 20230, 20233, 20234, 20240, 20241, 20245, 20250, 20260, 20270, 20271, 20272, 20280, 20281, 20282, 20290, 20291, 20292.

22-18 AWG: Part Nos. 50020, 50030, 50040, 50040M, 50041, 50042, 50044, 50050, 50051, 50052, 50055, 50060, 50061, 50062, 50070, 50071, 50072.

16-14 AWG: 50085, 50086, 50090, 50100, 50100M, 50101, 50102, 50103, 50104, 50105, 50110, 50114, 50120, 50140, 50141, 50142, 50150, 50151, 50152, 50160, 50161, 50162.

12-10 AWG: 50130, 50210, 50220, 50230, 50233, 50234, 50240, 50241, 50245, 50250, 50260, 50270, 50271, 50272, 50280, 50281, 50282, 50290, 50291, 50292.

TO THE REQUIREMENTS OF C22.2 NO 188-04:

- Un-insulated butt splices, Part Nos 10080, 10170 and 10310.
- Insulated type, butt splices, extruded vinyl, Part Nos 20080, 20170, 20310.

Notes:

1. Additional suffix "N" denotes moulded nylon insulation.
2. Insulated vinyl and nylon are rated 75C, 600V.
3. For solid and stranded 22-10 AWG copper conductors.
4. Crimp tools:
NH-1 22-10 gauge un-insulated
NH-13 12-10 gauge insulated
AK112 22-14 gauge insulated

/ey